

CERTIFICATE

No. Z2 076729 0106 Rev. 02

Holder of Certificate:

Seraphim Solar System Co.,Ltd.

No.1-2, Hengyao Rd, Henglin Zhen

Wujin District 213101 Changzhou

PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

704061801211-02

Valid until:

2024-04-23

Date,

2019-04-26

(Zhulin Zhang)

John John



CERTIFICATE

No. Z2 076729 0106 Rev. 02

Model(s):

SRP-xxx-6PA, (xxx=300-350, in step of 5) SRP-xxx-6PB, (xxx=250-290, in step of 5) SRP-xxx-6PA-HV, (xxx=300-350, in step of 5) SRP-xxx-6PB-HV, (xxx=250-290, in step of 5) SRP-xxx-E11A, (xxx=340-380, in step of 5) SRP-xxx-E11B, (xxx=285-315, in step of 5) SRP-xxx-E11A-HV, (xxx=340-380, in step of 5) SRP-xxx-E11B-HV, (xxx=285-315, in step of 5) SRP-xxx-BPA, (xxx=310-355, in step of 5) SRP-xxx-BPB, (xxx=255-295, in step of 5) SRP-xxx-BPC, (xxx=280-320, in step of 5) SRP-xxx-BPA-HV, (xxx=310-355, in step of 5) SRP-xxx-BPB-HV, (xxx=255-295, in step of 5) SRP-xxx-BPC-HV, (xxx=280-320, in step of 5) xxx stands for rated output power at STC.

Parameters:

Safety Class:

Max. System Voltage:

Construction:

Fire Safety Class:

Severity of Salt Mist Test:

Class II

1000V DC or 1500 V DC Framed, with Junction box. cable and connector.

Class C according to UL790

Level 6

Tested

according to:

IEC 61215-1(ed.1) IEC 61215-1-1(ed.1)

IEC 61215-2(ed.1)

IEC 61701(ed.2) IEC 61730-1(ed.2) IEC 61730-2(ed.2)

Production Facility(ies): 004571, 076729, 095290, 098633